



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7
आजादी का
अमृत महोत्सव

No. F6/DFS/MS/School/WZ/2022/ 718

Dated: 28/06/2022

FIRE SAFETY CERTIFICATE

Certified that the Lavi Public School Located at Plot No. 141, Main Narela Road, Village Ghevra, New Delhi-110081 comprised of Ground + 03 Upper Floors only & earlier the School building comprised of Ground + 02 Upper Floors was issued Fire Safety Certificate by this department Vide Letter No. F6/DFS/MS/School/2018/1741 dated 26.07.2018, owned/occupied by Lavi Public School have complied with the fire prevention and fire safety requirements in accordance with D.O.E Cr. No. 3298-3398 dated 01.03.2011 and Verified by the officer concerned of Fire Service on 13.06.2022 in the presence of Sh. Parveen Rana (Gen. Secretary) and that the premises/building is fit for occupancy class "Educational Building" Group B with effect from 28/6/2022 for a period of three years, subject to compliance of the conditions, printed below.

Issued on 28/6/2022 at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054.
2. The Principal, Lavi Public School, Plot No. 141, Main Narela Road, Village Ghevra, New Delhi-110081.

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.